

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AC0025

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SIMONSWERK UK Ltd – DPBW Brass Butt Hinges
See Annex A

1240	1250	P1260	1270	1280	P1285
1440	1450	P1460	1470	1480	P1485

Intended use: For use on fire/smoke compartmentation doors, and escape route doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence: 128790, 128791, 129145 Fire Test Evidence: C132467	
Self-closing Initial friction torque (door mass 40kg) Static load Load deformation	<2 Nm Passed with a displacement under load: -lateral <2 mm -vertical <4 mm and a residual displacement after unloading. -lateral <0.6 mm -vertical <0.3 mm	EN 1935:2002
Overload Shear strength Hinges for use on fire-resistant and/or smoke-controls doors	Passed Passed with a lateral and vertical displacement after unloading < 3 mm Grade 1: suitable for use on fire/smoke resistant door assemblies	
Durability Families of hinges with common design features Corrosion resistance	Passed a 200,000 cycles test with a maximum wear: -lateral <0.5 mm -vertical <1.0 mm and with a maximum frictional torque. -after 20 cycles <2 Nm -after the completion of 200,000 cycles <2 Nm The hinge covered by this CPR is the hinge tested Grade 4: 240 hours	EN 1935:2002
Dangerous substances	Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	EN 1935:2002

Certificate of constancy of performance

2812-CPR-AC0025

Placed on the Market under the Name of

**SIMONSWERK UK Ltd
Burcot Works
Spring Street
Tipton
West Midlands
DY4 8TF**

and produced in the manufacturing plant

E/008

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 1935: 2002

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 11/11/2020 and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **24/10/2022**

ERO Project Reference: **EROWF10443**



Paul Duggan
Certification Manager



Annex A

Hinge Reference	Description
1440	100 x 65mm DPBW Brass Finial Butt Hinges
1450	100 x 75mm DPBW Brass Finial Butt Hinges
P1460	100 x 100mm DPBW Brass Finial Projection Hinges
1470	127 x 75mm DPBW Brass Finial Butt Hinges
1480	152.4 x 75mm DPBW Brass Finial Butt Hinges
P1485	152.4 x 100mm DPBW Brass Finial Projection Hinges
1240	100 x 65mm DPBW Brass Butt Hinges
1250	100 x 75mm DPBW Brass Butt Hinges
P1260	100 x 100mm DPBW Brass Projection Hinges
1270	127 x 75mm DPBW Brass Butt Hinges
1280	152.4 x 75mm DPBW Brass Butt Hinges
P1285	152.4 x 100mm DPBW Brass Projection Hinges

